

# HOOVER TREATED WOOD PRODUCTS, INC.

## *TECHNICAL NOTE*

*FOR ADDITIONAL INFORMATION: 1-800-TEC-WOOD (832-9663)*

### **CLASS A-B-C/I-II-III FLAME SPREAD, CLASS A-B-C ROOF COVERINGS, AND HOURLY FIRE RESISTANCE RATINGS**

Flame spread index, roofing classes and hourly ratings are confusing terms and they sometimes get misused. Flame Spread Index is based on the ASTM E-84/UL 723 “Test for Surface Burning Characteristics of Building Materials”; Roof Covering Class is based on ASTM E-108/UL 790, “Test for Fire Performance of Roofing Materials”; Hourly resistance ratings are determined for assemblies based on ASTM E-119 “Fire Tests of Building Materials.”

#### **FLAME SPREAD INDEX**

ASTM E-84/UL 723 classifies products by the flame spread index. The index is a numerical reference and is determined by the response of the material during a ten minute test.

Class A or I: Flame spread Index 25 or less  
Class B or II: Flame spread Index 26 to 75  
Class C or III: Flame spread Index 76 to 200

The International Building Code and International Residential Code (IBC / IRC) requires that material described as Fire Retardant Treated Wood (FRTW) must have a flame spread index of 25 or less in the 10-minute ASTM E-84/UL 723 test, **and when the test is continued for an additional 20 minutes:**

there shall be no evidence of significant progressive combustion, and the flame front shall not progress more than 10.5 feet from the centerline of the burner.

**These additional requirements distinguish FRTW from surface coatings and any other building material.**

#### **CLASS A-B-C ROOF COVERINGS**

There is no correlation between Class A flame spread and Class A roof Coverings. ASTM E-108/UL 790 roof covering test is a pass-fail test under which a product either passes the criteria as a Class A, B, or C roof covering system or it doesn't. The highest fire classification for a roof covering is Class A. Note that a Class C roof covering is considered to be classified for fire rating, while a Class C building material is not. Non-classified roof systems have no fire rating.

#### **HOURLY FIRE RESISTANCE RATINGS**

Hourly ratings are a function of the assembly being used (wall, floor/ceiling, door etc.) and generally require use of a noncombustible material (gypsum, masonry). ASTM E-119 “Fire Tests of Building Construction Materials” is the test used to determine the hourly resistance rating of an assembly. It exposes an assembly to heat and flame on one side and tests for heat transmission, burn-through, and the ability to withstand a hose stream from a fire hose.

The extended 30 minute requirements of the building code for FRTW has no relation to a 30-minute or other hourly rating, which must be determined by ASTM-E119. Fire Retardant Treated Wood cannot be substituted for type-X gypsum in a rated assembly and achieve the same hourly rating. FRTW's advantage over untreated wood and other combustible materials is the fact that it doesn't ignite or contribute to the spread of flame. Building codes often allow this substitution which means wood can be used in non-combustible construction.

DISCLAIMER OF LIABILITY FOR RELIANCE ON INFORMATION PROVIDED BY HOOVER TREATED WOOD PRODUCTS, INC.: The information contained herein is true and accurate to the best of our knowledge, but is provided without warranty or guarantee. Since the conditions of use are beyond our control, Hoover Treated Wood Products, Inc. ("Hoover"), disclaims all liability and assumes no legal responsibility for damages resulting from use of or reliance upon the information contained herein.