

# HOOVER TREATED WOOD PRODUCTS, INC

## **TECHNICAL NOTE**

FOR ADDITIONAL INFORMATION: [www.frtw.com](http://www.frtw.com) or 1-800-TEC-WOOD (832-9663)

### **SPECIFICATIONS**

#### **MICRO-GUARD® Preservative Treated Wood**

##### **Part 1 – General Product Information**

- A. **MICRO-GUARD®** is pressure impregnated, preservative treated lumber, timbers, poles, post, plywood, and other wood materials. It is designed for use in applications required by code to be protected against fungal decay and termites or where use of preservative treated wood is appropriate.
- B. **MICRO-GUARD®** treated wood products are manufactured in accordance with ICC ESR-2240.
- C. **MICRO-GUARD®** treated wood products are manufactured in accordance with the American Wood Protection Association (AWPA) P61, U1 and T1 Standards.
- D. **MICRO-GUARD®** treated wood products are approved for interior and exterior uses above ground, ground and fresh water contact and for critical structural members in contact with the ground.
- E. **MICRO-GUARD®** is recommended to be KDAT (kiln dried after treatment).
- F. **MICRO-GUARD®** treated wood products are produced under accredited third party review and carry the stamp of an approved third party agency.
- G. **MICRO-GUARD®** does not contain Chromium, Arsenic or Urea formaldehyde.

##### **Part 2 – Preservative Treatment**

- A. Treatment shall be **MICRO-GUARD®** provided by Hoover Treated Wood Products, Inc
- B. **MICRO-GUARD®** treated wood that is KDAT will be dried to a moisture content of 19% or less for lumber and 18% or less for plywood.
- C. **MICRO-GUARD®** treated wood meets the applicable building code requirements for above ground and ground contact use.
- D. Plywood treated with **MICRO-GUARD®** shall be manufactured under US Product Standard PS 1 or PS 2. Panels shall have a minimum bond durability of Exposure 1.
- E. Grade marked lumber treated with **MICRO-GUARD®** shall be in accordance with PS 20.
- F. The specifier shall indicate lumber or plywood of the appropriate size, grade, specie, retention, and drying requirement necessary for the design criteria of the intended use.

##### **Part 3 – Execution and Applications**

###### **3.01 Applications**

The following AWPA Use Categories (UC) describes exposure conditions that **MICRO-GUARD®** treated wood products may be subject to.

- UC1 Interior Dry
- UC2 Interior Damp
- UC3A Exterior Above Ground, Coated with Rapid Water Runoff
- UC3B Exterior Above Ground, Uncoated or Poor Water Runoff

DISCLAIMER OF LIABILITY FOR RELIANCE ON INFORMATION PROVIDED BY HOOVER TREATED WOOD PRODUCTS, INC.: The information contained herein is true and accurate to the best of our knowledge, but is provided without warranty or guarantee. Since the conditions of use are beyond our control, Hoover Treated Wood Products, Inc. ("Hoover") disclaims all liability and assumes no legal responsibility for damages resulting from use of or reliance upon the information contained herein

- UC4A                Ground Contact, General Use
- UC4B                Ground Contact, Heavy Duty
- UC4C                Ground Contact, Extreme Duty

Locations requiring preservative-treated wood for decay or termite resistance are described in Section 2304.12 of the International Building Code (IBC) and Sections R317, R318 and R402.1.2 of the International Residential Code (IRC).

### 3.02 Fasteners

- A. Fasteners used with **MICRO-GUARD**<sup>®</sup> must be in accordance with Section 2304.9.5 of the IBC and Section R319.3 of the IRC, except that aluminum fasteners are permitted.
- B. Galvanized fasteners may be used for many exterior applications. Fasteners, nails and screws should conform to ASTM-A153 (1 oz/ft<sup>2</sup>). Hardware, such as connectors, joist hangers, etc. shall conform to ASTM – A653 G90 (0.90 oz/ft<sup>2</sup>).
- C. Aluminum or aluminum based fasteners and other building products (flashing, siding, etc.) may be placed in direct contact with **MICRO-GUARD**<sup>®</sup> when used for code compliant interior or above ground applications, such as decks, or fencing. Applications must provide proper water drainage and not allow the wood to be exposed to standing water or to water immersion.
- D. Stainless Steel (Type 304 and 316) fasteners are required for Permanent Wood Foundations below grade and are recommended for use with treated wood in other severe exterior applications such as swimming pools, salt water exposure and other critical environments.
- E. Carbon steel fasteners may be used for UC1 and UC2 interior, aboveground, weather-protected applications such as sill plates, interior framing and interior trusses.
- F. Trapped water or moisture leads to conditions that favor corrosion. **MICRO-GUARD**<sup>®</sup> should not be used in conditions where these conditions will exist. Where design or actual conditions allow for constant, repetitive or long periods of wet conditions, only stainless steel fasteners should be used.