



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
 OFFICE OF THE STATE FIRE MARSHAL
 FIRE ENGINEERING & INVESTIGATIONS DIVISION
 BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	2580-1701:0101
CATEGORY:	2580 - PLYWOOD
LISTEE:	HOOVER TREATED WOOD PRODUCTS, INC. 154 WIRE ROAD, THOMSON, GA, 30824 Contact: Athari,Chris (706) 755-5350 (706) 595-6600 Email: cathari@frtw.com
DESIGN:	Treated Plywood with EXTERIOR FIRE X. Products are pressure impregnated with "EXTERIOR FIRE X" fire retardant chemical. EXTERIOR FIRE X covers the following types of plywood: Douglas Fir Plywood, Micro-Lam Douglas Fir laminated lumber plywood, Southern Yellow Pine Plywood, Gang-Lam Southern Yellow Pine laminated lumber plywood, Micro-Lam Southern Yellow Pine laminated lumber plywood, and Spruce Master Plank laminated lumber plywood. Refer to listee's printed installation instructions for additional detailed product description and constructions.
RATING:	Species Flame Spread Smoke Developed (30 minutes) (30 minutes) Douglas Fir 10 45 Micro-Lam Douglas Fir 10 25 Southern Yellow Pine 15 50 Gang-Lam Southern Yellow Pine 10 5 - 50 Micro-Lam Southern Yellow Pine 10 25 Spruce Master Plank 10 30
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, product identification, classification, and Underwriter's Laboratory label.
APPROVAL:	Listed as exterior type fire retardant treated plywood. Also approved for use as ignition resistant materials as specified in Chapter 7A of the *California Building Code. The plywood must be pressure treated with the fire retardant chemical at the factory under authorized service inspection.
NOTES:	



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

Corrected 9-25-12
ii



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 03/24/2023

Listing Expires: 06/30/2024

Authorized By: **Victor Wong**, Program Coordinator
Fire Engineering & Investigations Division