



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
 OFFICE OF THE STATE FIRE MARSHAL
 FIRE ENGINEERING & INVESTIGATIONS DIVISION
 BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	2520-1701:0100
CATEGORY:	2520 - TREATED LUMBER
LISTEE:	HOOVER TREATED WOOD PRODUCTS, INC. 154 WIRE ROAD, THOMSON, GA, 30824 Contact: Athari, Chris (706) 755-5350 (706) 595-6600 Email: cathari@frtw.com
DESIGN:	Treated Lumber with EXTERIOR FIRE X. Products are pressure impregnated with "EXTERIOR FIRE X" fire retardant chemical. EXTERIOR FIRE X covers the following types of lumber: Douglas Fir, Southern Yellow Pine, Western Red Cedar, and Redwood Lumber. Refer to listee's printed installation instructions for additional detailed product description and constructions.
RATING:	Douglas Fir: 15 Flame Spread; 30 Smoke Developed Southern Yellow Pine:15 Flame Spread; 50 Smoke Developed Western Red Cedar:10 Flame Spread; 30-105 Smoke Developed Redwood:10 Flame Spread; 10-115 Smoke Developed *Tested to ASTM E84 with an additional 20 minutes and ASTM D2898.
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, product identification, classification, and Underwriter's Laboratory label.
APPROVAL:	Listed as exterior type fire retardant treated lumber. Also approved for use as ignition resistant materials as specified in Chapter 7A of the *California Building Code. The lumber must be pressure treated with the fire retardant chemical at the factory under authorized service inspection.
NOTES:	

*Rev. 3-30-23
 DAL



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 04/05/2024

Listing Expires: 06/30/2025

Authorized By: **David Castillo**, Program Coordinator
Fire Engineering & Investigations Division